

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1483:103 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Mirtone, 90 Fieldstone Ct., Cheshire, CT 06410
Contact: Brad Miller (888) 649-9827 Fax (203) 699-3108

DESIGN: Models BS-3AR, BS-5AR, BS-7AR and BS-8AR adapter plate strobe lights. Unit consists of a separately listed strobe light mounted on an adapter plate. It is designed to allow an add-on of listee's separately listed Models 74328U and 74330U bell (CSFM Listing No. 7135-mirtone:ccc PENDING). Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Candela: -5A: 15cd
-3A: 30cd
-7A: 15/75cd
-8A: 110cd

Electrical: 20 - 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, candela/electrical rating and UL label.

APPROVAL: Listed as an adapter plate with strobe light for use with separately listed compatible fire alarm control units. Suitable for the hearing impaired and for indoor use only.

XLF: 7125-1388:209

03-26-97



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**